

This item has been discontinued and as of 31.12.2017, can no longer be delivered.



## Data sheet | Item number: 201-622

Transformer fuse terminal block; orange

[www.wago.com/201-622](http://www.wago.com/201-622)



### Data

#### Electrical data

#### Ratings per IEC/EN 60664-1

Rated voltage (III / 2)	250 V
Rated impulse voltage (III / 2)	4 kV
Rated current	6.3 A
Legend (ratings)	(III / 2) ≙ Overvoltage category III / Pollution degree 2

Subject to changes. Please also observe the further product documentation!

WAGO Kontakttechnik GmbH & Co. KG  
Hansastr. 27  
32423 Minden  
Phone: +49571 887-0 | Fax: +49571 887-169  
Email: [info.de@wago.com](mailto:info.de@wago.com) | Web: [www.wago.com](http://www.wago.com)

Do you have any questions about our products?  
We are always happy to take your call at +49 (571) 887-44222.

This item has been discontinued and as of 31.12.2017, can no longer be delivered.



## Data sheet | Item number: 201-622

[www.wago.com/201-622](http://www.wago.com/201-622)

### Approvals per UL 1059

Approvals per UL 1059

### Connection data

Connection technology	Screw clamp connection
Strip length	10 ... 12 mm / 0.39 ... 0.47 inch
Connection technology 2	Solder contact
Total number of connection points	1
Total number of potentials	1
Number of connection types	1

### Geometrical Data

Width	22 mm / 0.866 inch
Height	26.5 mm / 1.043 inch
Depth	23.4 mm / 0.921 inch

### Material Data


Color	orange
Weight	8 g

### Commercial data

Product Group	10 (Transformer Blocks)
Packaging type	bag
Country of origin	PL
GTIN	4045454299989
Customs Tariff No.	85369095990

### Approvals / Certificates

#### Country specific Approvals

Logo	Approval	Additional Approval Text	Certificate name
	CSA DEKRA Certification B.V.	C22.2	70010891

Subject to changes. Please also observe the further product documentation!

WAGO Kontakttechnik GmbH & Co. KG  
Hansastr. 27  
32423 Minden  
Phone: +49571 887-0 | Fax: +49571 887-169  
Email: [info.de@wago.com](mailto:info.de@wago.com) | Web: [www.wago.com](http://www.wago.com)

Do you have any questions about our products?  
We are always happy to take your call at +49 (571) 887-44222.


This item has been discontinued and as of 31.12.2017, can no longer be delivered.



## Data sheet | Item number: 201-622

[www.wago.com/201-622](http://www.wago.com/201-622)

### UL-Approvals

Logo	Approval	Additional Approval Text	Certificate name
	UR Underwriters Laboratories Inc.	UL 1059	20160630- E45172

### Counterpart

#### Downloads

#### Documentation

##### Additional Information

Technical explanations	Apr 3, 2019	pdf 3.6 MB	Download
------------------------	-------------	---------------	----------

### CAD/CAE-Data

#### CAD data

2D/3D Models 201-622	URL	Download
----------------------	-----	----------

#### CAE data

EPLAN Data Portal 201-622	URL	Download
---------------------------	-----	----------

### Installation Notes

Subject to changes. Please also observe the further product documentation!

WAGO Kontakttechnik GmbH & Co. KG  
Hansastr. 27  
32423 Minden  
Phone: +49571 887-0 | Fax: +49571 887-169  
Email: [info.de@wago.com](mailto:info.de@wago.com) | Web: [www.wago.com](http://www.wago.com)

Do you have any questions about our products?  
We are always happy to take your call at +49 (571) 887-44222.